



Certificate of Compliance

Certificate: 70019589

Master Contract: 262866

Project: 70019589

Date Issued: March 26, 2015

Issued to: CHangshu Friends Connector

Technology Co., Ltd
No.2, Zhongtian Road
Changshu, Jiangsu 215500
China
Attention: Yifeng Wang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Rex Yao

Issued by: Rex Yao

PRODUCTS

CLASS 6234 82 - RECEPTACLES-Connectors for Photovoltaic - Systems - Certified to US Standards

CLASS 6234 02 - RECEPTACLES - Connectors for Photovoltaic Systems

PV locking connectors, suitable for the termination of single, insulated, stranded copper type USE-2 or Photovoltaic Wire (PV Wire) rated 90°C, 105°C, 125°C, or 150°C dry; 90°C wet; 1000 Vdc or 600Vdc, No. 12 AWG.

Model PV2a, consisting of male and female connectors, rated 600 V dc, 16 A;

Model PV2b, consisting of male and female connectors, rated 1000 V dc, 16 A;

Model PV3a, consisting of male and female connectors, rated 600 V dc, 20 A;

Model PV3b, consisting of male and female connectors, rated 1000 V dc, 20 A

Notes:

The connectors are certified as a component only for use on PV panels where the suitability of the final combination is to be determined by CSA International.



Certificate: 70019589

Master Contract: 262866

Project: 70019589

Date Issued: March 26, 2015

APPLICABLE REQUIREMENTS

CSA C22.2 No 182.5 - Photovoltaic Connectors

UL 6703 (Subject) - Connectors For Use in Photovoltaic Systems